1 General

Fan type	Fan
Rotating direction looking at rotor	Counterclockwise
Airflow direction	Air outlet over struts
Bearing system	Ball bearing
Mounting position - shaft	Any
Balancing grade	40,0

2 Mechanics


2.1 General

Width	92,0 mm	
Height	92,0 mm	
Depth	25,0 mm	
Diameter	0,0 mm	
Mass	0,280 kg	
Housing material	Metal	
Impeller material	Plastic	

2.2 Connections

Electrical connection	Wires	
Lead wire length	L = 310 mm	
Tolerance	+- 10 mm	
Tube length	See drawing	
Tolerance		
Wire size (AWG)	22	
Insulation diameter		
Plug	See drawing	
Contact	See drawing	





	Color	Operation
1	black	L
2	black	Ν

3 Operating Data


3.1 Electrical Operating Data

Measurement
conditions:Normal air density = 1,2 kg/m3; Temperature 23° +/- 3° ; Motor axis horizontal;warm-up
time before measuring 5 minutes (unless otherwise specified).
In the intake and outlet area should not be any solid obstruction within 0,5 m.

$\Delta p = 0$	corresp. to free air flow (see chapter aerodynamics)
l:	corresp. to RMS line current

Features	Condition	Symbol	Values			
Frequency	$\Delta p = 0$	f	50 Hz		60 Hz	
Nominal voltage	$\Delta p = 0$	U _N	11	5 V	11	5 V
Tolerance			+ 6 %	- 10 %	+6%	- 10 %
Power consumption			8,1 W		6,5 W	
Tolerance	$\Delta p = 0$	Р	+ 5 %	- 10 %	+ 5 %	- 10 %
Speed			1.590 1/min		1.990 1/min	
Tolerance	$\Delta p = 0$	n	+- 1	0 %	+- ′	10 %

3.2 Electrical Features



3.3 Aerodynamics

Measurement
conditions:Measured with a double chamber intake rig acc. to DIN EN ISO 5801.
Normal air density = 1,2 kg/m3; Temperature 23°C +/ - 3°C;
In the intake and outlet area should not be any solid obstruction within 0,5 m. Motor shaft
horizontal.
The information is only valid under the specified test conditions and may be changed by the
installation conditions. If there are deviations from the standard test conditions, the
characteristic values must be checked under the installed conditions.

a.) Operation condition: 1.590 1/min at free air flow

Frequency: 50 Hz

Max. free-air flow ($\Delta p = 0 / \dot{V} = max.$)	31,0 m3/h
Max. static pressure ($\Delta p = max. / \dot{V} = 0$)	15 Pa

b.) Operation condition:

1.990 1/min at free air flow Frequency: 60 Hz

Max. free-air flow ($\Delta p = 0 / \dot{V} = max.$)	39,0 m3/h
Max. static pressure ($\Delta p = max. / \dot{V} = 0$)	24 Pa

3.4 Sound Data

Measurement
conditions:Sound pressure level: 1 meter distance between microphone and the air intake.
Sound power level: Acc. to DIN 45635 part 38 (ISO 10302)Sound power level: Acc. to DIN
45635 part 38 (ISO 10302)
Measured in a semianchoic chamber with a background noise level of Lp(A) < 5 dB(A)
For further measurement conditions see chapter aerodynamics.

a.) Operation condition:

1.590 1/min at free air flow	Frequency: 50 Hz

Optimal operating point	26,0 m3/h @ 3 Pa	
Sound power level at the optimal operating point	3,3 bel(A)	
Sound pressure level at free air flow, measured in rubber bands	15,0 dB(A)	

b.) Operation condition:

1.990 1/min at free air flow

Frequency: 60 Hz

Optimal operating point	29,0 m3/h @ 7 Pa	
Sound power level at the optimal operating point	3,9 bel(A)	
Sound pressure level at free air flow, measured in rubber bands	19,0 dB(A)	

4 Environment

4.1 General

Min. permitted ambient temperature TU min.	-40 ℃ / 50 Hz -40 ℃ / 60 Hz	
Max. permitted ambient temperature TU max.	80 ℃ / 50 Hz 80 ℃ / 60 Hz	
Min. permitted storage temperature TL min.	-40 °C	
Max. permitted storage temperature TL max.	80 °C	

4.2 Climatic Requirements*)

Humidity requirements	humid heat, cyclic; according to DIN EN 60068-2-30,	
	6 cycle	
Water exposure	None	
Dust requirements	Dust check; according to DIN EN 60068-2-68,	
	6g/m2d, 1 day	
Salt fog requirements	None	

Permitted application area:

The product is for the use in sheltered rooms with limited controlled temperature. Occasionally condensed water is allowed. Direct exposure to water must be avoided. Saline ambient conditions must be avoided.

Pollution degree 2 (according DIN EN 60664-1)

It occurs only non-conductive pollution. Occassionally, temporary conductivity caused by condensation occurs.

5 Safety

5.1 Electrical Safety

Dielectric strength DIN EN 60950 (VDE 0805) and DIN EN 60335 (VDE	
0700) A.) Type test Measuring conditions: After 48h of storage at 95%	1000 VAC / 1 Min.
R.H. and 25°C. No arcing or breakdown is allowed!	
All connections together to ground. B.) Routine test	1500 VAC / 1 Sec.
Measuring conditions: At indoor climate. No arcing or breakdown is allowed!	1300 VAC / 1 Sec.
All connections together to ground.	
Isolation resistance Measuring conditions: After 48h of storage at 95%	RI > 50 MOhm
R.H. and 25° measured with U=500 VDC for 1 min.	
Clearance / creepage distance	2,0 mm / 1,1 mm
Protection class	

5.2 Approval Tests

CE	EC Declaration of Conformity	Yes
EAC	Eurasian Conformity	Yes
UL	Underwriters Laboratories	Yes / UL507, Electric Fans
VDE	Association for Electrical, Electronic and	Yes / Approval acc. to EN 60950 (VDE 0805) - Information
	Information Technologies	technology equipment
CSA	Canadian Standards Association	Yes / C22.2 No. 113 Fans and Ventilators
CCC	China Compulsory Certification	Yes / GB 12350 Safety Requirements for small Power Motors

The approval tests are observed to: U approval max.: 115 V / f: 50 and 60 Hz @ TU approval max.: 80 $^{\circ}{\rm C}$

6 Reliability

6.1 General

Life expectancy L10 at TU = 40 $^{\circ}$ C	70.000 h / 50 Hz 70.000 h / 60 Hz	
Life expectancy L10 at TU max.	27.500 h / 50 Hz 27.500 h / 60 Hz	

